

Temperaturmessung des Gehäuses: DE001-02 in Massivdecke 18 cm  
Masse des Deckenaufbaus 250 kg/m<sup>2</sup>  
EVG: Elektronischer Transformator 200W  
Messpunkt auf der Betonfläche oberhalb Transformator



Umgebungstemperatur 19° C

Betriebsstunden (h)	Temperatur C° (T)
0	19
1	23
2	24
3	27
4	28
5	29
6	30
7	30
8	31
9	31
10	32
11	33
12	33
13	33
14	34
15	34
16	34
17	34
18	34
19	34
20	34
21	34
22	34
23	34
24	34

