

Temperaturmessung des Gehäuses: DE001-02 in Massivdecke 18 cm
Masse des Deckenaufbaus 250 kg/m²
EVG: Elektronischer Transformator 100W
Messpunkt auf der Betonfläche oberhalb Transformator



Umgebungstemperatur 19° C

Betriebsstunden (h)	Temperatur C° (T)
0	19
1	22
2	25
3	27
4	27
5	28
6	29
7	29
8	29
9	30
10	30
11	30
12	30
13	30
14	30
15	30
16	30
17	30
18	30
19	30
20	30
21	30
22	30
23	30
24	30

